

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. CHCFTS/1934Date: 27/02/21

It is certified that an inspection headed by Dr. Mukesh Bhandari (Name of Officers with designation) from MOFLC (Name of Department/Office) inspected the RASA International School, Dulhara Road, Fatehpur Sikri, Agra has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central / State / U.T. Govt.

The above certificate is valid for the period of one year.

Signature with seal.....[Signature]Name.....Medical SupritendentDesignation.....CHC Fatehpur Sikri
Agra

To

.....
.....
.....

(Name & Address of the Institution)

[Signature]

प्रबन्धक

रासा इण्टरनेशनल स्कूल
दुल्हारा रोड, फतेहपुर सीकरी, अग्रा

[Signature]


Principal

RASA International School
Fatehpur Sikri, Agra-283110

Scanned with CamScanner

GSTIN: 09BATPS9741Q2Z7

ESTD: 2001



ANALYSIS[®]



8057166366

7351578078

8279928580

INDUSTRIAL RESEARCH & QUALITY CONTROL LABS

D-1043/L.I.G., BEHIND WELFARE HOSP. KALINDI VIHAR, FIROZABAD ROAD, AGRA-06

Website: www.analysislabs.in Email: analysislabs@gmail.com

TESTING & CERTIFICATION TO GLOBAL STANDARDS & SPECIFICATIONS

(Government Approved Industrial Testing, Research & Development Laboratory)

{ISO 9001 & 14001-2015 Certified Lab and Govt. approved lab {Not.no.1879/17-09-07-11-1(2) 2006}

Ref.No.-ANALY./Chem/02/21

TEST CERTIFICATE

Dt.- 23-02-2021

ISSUED TO :

M/S RASA International School
Dulhara Road, Fatehpur Sikri
Distt.-Agra (U.P.)-283110

PARTY'S REFERENCE :

Test request Date - 22-02-2021
Sample Submitted on -22-02-2021
Date of Testing : 23-02-2021

SAMPLE DESCRIPTION :


One Sample of R.O. treated Water in a
food grade plastic bottle.
Qty.--1.0 l approx.

TEST SPECIFICATION :

Physico-Chemical Analysis of Treated water
for selected parameters.
Ref. Stds.-IS: 3025, IS:14543-2004

RESULTS

S.No.	TESTS	UNITS	RESULTS	IS:14543-2004 LIMITS	TEST METHOD
1.	pH Value at 27 °C	-----	6.84	6.5-8.5	IS:3025(part-11)
2.	Total Dissolved Solids	mg/l	137	500 max.	IS:3025(part-16)
3.	Chlorides as Cl	mg/l	16	200 max.	IS:3025(part-32)
4.	Alkalinity as HCO ₃	mg/l	85	200 max.	IS:3025(part-23)
5.	Calcium as Ca	mg/l	06	75 max.	IS:3025(part-40)
6.	Magnesium as Mg	mg/l	04	30 max.	IS:3025(part-46)
7.	Sulphate as SO ₄	mg/l	09	200 max.	IS:3025(part-24)
8.	Colour	Colour unit	0.20	2.0 max.	IS:3025(part-4)



Note : -1. Test Results listed refer only to the sample and applicable parameters. Total Liability of the ANALYSIS is limited to the invoiced amount only. 2. This is not to be reproduced wholly or in part and can not be used as an

REFERENCE STANDARDS: ISI. BS. ASTM. SAE. AISI. DIN. JIS. WHO. VSM. SIS. NF. HA. ISO

CALIBRATION, WATER FOR ALL APPLICATIONS. FERROUS, NON-FERROUS METALS, ORES & ALLOYS. CONSTRUCTION MATERIALS. CHEMICALS. MINERALS. COAL & COKE. REFRACTORIES METAL OXIDES. GLASSES & CERAMICS. TEA & COFFEE. PETROLEUM PRODUCTS. BITUMEN & COALTAR. LUBRICANTS & GREASES. RUBBERS. PLASTIC & LEATHER FOOD PRODUCTS. DAIRY PRODUCTS. ICE CREAM. VEGETABLE OILS & SOAPS. PAINT VARNISHES & ENAMELS. EFFLUENTS DISCHARGE & INDUSTRIAL WASTE CONSTRUCTION CHEMICALS. JOINT & SEALENTS. WATER PROOFING & DAMP PROOFING COMPOUNDS. DETERGENTS & SOAPS. BAKERY PRODUCTS. INSECTICIDES AND PESTICIDES. FERTILIZERS. METALLOGRAPHY. ADULTERANTS. PRESERVATIVES. LAB TRAINING & PROJECT CONSULTANCY FOR SETTING UP IN HOUSE LABORATORY. NEW PRODUCT DEVELOPMENT CONSULTANCY.

Prabandhak

प्रबन्धक

रासा इण्टरनेशनल स्कूल
दुल्हारा रोड, फतेहपुर सीकरी, आगरा

Principal

Principal

RASA International School
Fatehpur Sikri, Agra-283110